



MOFFAT WATER SUPPLY CORPORATION SERVICE INSPECTION CERTIFICATION

Name of PWS: Moffat Water Supply Corporation
5460 Lakeaire Blvd.
Temple, TX 76502

Date: _____
PWS I.D.: 0140028
254-986-2457

Location of Service _____ Owner Name _____

I _____, upon inspection of the private water distribution facilities connected to the aforementioned public water supply do hereby certify that, to the best of my knowledge:

	Compliance	Non-Compliance
(1) No direct connection between the public drinking water supply and a potential source of contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with commission regulations.	<input type="checkbox"/>	<input type="checkbox"/>
(2) No cross-connection between the public drinking water supply and a private water system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure-zone backflow prevention assembly is properly installed and a service agreement exists for annual inspection and testing by a certified backflow prevention device tester.	<input type="checkbox"/>	<input type="checkbox"/>
(3) No connection exists which would allow the return of water used for condensing, cooling or industrial processes back to the public water supply.	<input type="checkbox"/>	<input type="checkbox"/>
(4) No pipe or pipe fitting which contains more than 0.25% lead exists in private water distribution facilities installed on or after January 1, 2014.	<input type="checkbox"/>	<input type="checkbox"/>
(5) No solder or flux which contains more than 0.0% lead exists in private water distribution facilities installed on or after January 1, 2014.	<input type="checkbox"/>	<input type="checkbox"/>

Water service shall not be provided or restored to the private water distribution facilities until the above conditions are determined to be in compliance.

I further certify that the following materials were used in the installation of the water distribution facilities:

Service lines	Lead	<input type="checkbox"/>	Copper	<input type="checkbox"/>	PVC	<input type="checkbox"/>	Other	<input type="checkbox"/>
Solder	Lead	<input type="checkbox"/>	Lead Free	<input type="checkbox"/>	Solvent Weld	<input type="checkbox"/>	Other	<input type="checkbox"/>

I recognize that this document shall become a permanent record of the aforementioned Public Water System and that I am legally responsible for the validity of the information I have provided.

Signature of Inspector

Registration Number

Title

Type of Registration

Date